

HR100-CT User Manual


WARNING Disregarding this symbol may result in serious injury or death.

CAUTION Disregarding this symbol may result in injury or damage to equipment.


Note Special attention is required when this symbol is shown.

EN16005 Setting required to conform with EN16005.

1. DESCRIPTION



2. DIMENSIONS



3. LED INDICATORS

| | |
|---------------------------|--|
| Green | Standby. |
| Green blinking | Doorway Learning (When dip switch (Y) 5 is ON). |
| Blue | ROW 4,5 Detecting. |
| Red | ROW 1,2,3 Detecting. |
| Orange | Detection row "ROW1" ("ROW2" when doorway Learning is turned ON) is detecting door movement. |
| Orange blinking (Fast) | Indicates a change of dip switch settings. |
| Orange blinking (Slow) | Door Hold is turned Open (When dip switch (Y) 4 is Open). |
| Green/Red blinking (Fast) | Internal Sensor Error. |
| Green/Red blinking (Slow) | Reflected infrared signal from the floor is very low. |

5. TECHNICAL SPECIFICATIONS

| | | |
|-----------------------|--|--|
| Model Name | HR100-CT | |
| Detection Method | Active Infrared Reflection | |
| Installation Height | 3.0[m] (9.84 [ft]) Max | |
| Supply Voltage | AC/DC 12 to 24 [V] ±10% 50/60Hz | |
| Power Consumption | AC12V-2.1 [VA] (Max) | AC24V-2.1 [VA] (Max) |
| | DC12V-110 [mA] (Max) | DC24V-60 [mA] (Max) |
| Output Holding Time | Approx. 0.5s | |
| Response Time | 0.1s ~ 0.2s | |
| Presence Timer | Outer 2 Rows | 1 [seconds] |
| | Inner 3 Rows | 2s,30s,60s or ∞ |
| Output | ROW 1,2 | Open collector: 7.5 [mA] (Max) Resistor Load Opto coupler (NPN) Voltage: 55 [VDC] Max. Current : 50 [mA] Max. Dark Current: 100 [nA] Max. (Resistance load) |
| | ROW 2,3,4,5 | Form A Relay DC50 [V] 0.1[A] Resistor Load |
| Test Input | 6 [mA] Max. @ 24 [VDC] | |
| Operating Temperature | -20 to +60 [Deg.C], (-4 to 140 Deg.F) | |
| Operating humidity | Below 80% | |
| IP Rate | IP54 (With Base) | |
| Category | 2 , performance level D according to EN ISO 13849-1:2008 | |
| Weight | 0.55 [lb.] (0.25 [kg]) | |
| Color | Black, Silver | |
| Accessories | Cable, Mounting Screw 2pcs., Mounting Template, Installation Instruction | |

Notice: Specification may be changed without prior notice.

4. MOUNTING PRECAUTIONS

Mounting height is 3m (9.84ft) or lower.

Mount within 50mm from the bottom of the door engine cover.

Ensure there are no moving objects in the detection zone.

Ensure no condensation gets onto the sensor.

If the sensor is exposed to excessive rain install with a Hotron weather cover.

If possible ensure no accumulation of snow or water on the floor.

Ensure the minimum of reflected sunlight from the floor.

Use different frequency settings for sensors in close proximity.

To maximize the effectiveness of doorway detection, install the HR100-CT outside and inside as shown below.

6. MOUNTING & WIRING INFORMATION

WARNING Drilling may cause electric shock. Be careful of hidden wires inside the door engine cover.

- Attach the mounting template with its bottom parallel to the same position as the bottom edge of the door engine cover.
- Drill holes for mounting (3.5mm φ) and wiring (10mm φ) holes.
- If you need to remove the sensor body from its base then lift the sensor body from the base and tilt it forward to remove as illustrated.
- Attach the sensor with the mounting screws provided.

⑤-1 Wiring to a door controller that can test the sensor.

⑤-2 Wiring to a door controller that cannot test the sensor.

⑥ House connectors in the receptacle.

⑦ Replace Cover.

CAUTION Be careful not to inadvertently move the Depth Adjustment Lever Arms when replacing the cover.

7. DIP SWITCH SETTINGS

CAUTION

Dip Switch (X) Dip Switch (Y)

☆ = Default Setting

| Function | Dip Switch (X) | Description | Possible Setting Options |
|---|----------------|--|--|
| Presence Timer | ☆ 30s 1 2 | The sensor will detect a stationary object for the period of the preset presence timer setting on the inner 3 rows. EN16005 To comply with EN16005 set the presence timer to 30s or more. | 2s 1 2 ☆ 30s 1 2 60s 1 2 ∞ 1 2 |
| Quantity of Detection Rows | ☆ R5 3 4 | The number of rows of detection can be set to 5, 4, 3, 2 depending on detection area requirements. | 5 Rows ON ☆ R5 3 4 4 Rows ON R4 3 4 3 Rows ON R3 3 4 2 Rows ON R2 3 4 |
| Frequency | ☆ A 5 6 | When more than two sensors are installed in close proximity to each other select different frequency settings for each sensor to prevent cross interference. | ☆ A 5 6 B 5 6 C 5 6 D 5 6 |
| Safety Relay Output | ☆ N.O. 7 | Refer to [11.Timing Chart of events] for full details on Safety Output. | ☆ N.O. 7 Safety Output (Opto-Coupler) N.C. 7 |
| Reflection Diagnostics | ☆ Normal 8 | A low reflected infrared signal is indicated by a slow flashing Red/Green LED. To ignore this low reflection error, set this dip switch to "Low Reflection"(ON). EN16005 To comply with EN16005 set to "Normal". | ☆ Normal 8 Transmitter Receiver IR Spot Low Ref. 8 Transmitter Receiver IR Spot |
| Function | Dip Switch (Y) | Description | Possible Setting Options |
| Direction Detection | ☆ OFF 1 | When set to ON, pedestrians moving away from the sensor will not be detected. Note For pedestrian safety purposes when "Doorway Learn" is set to ON the 1 st and 2 nd row of detection will detect pedestrians regardless of direction of movement. | ☆ OFF 1 ON 1 |
| Activation Relay Output | ☆ N.O. 2 | Refer to [11.Timing Chart of events] for full details on Activation Output. | ☆ N.O. 2 Activation Output (Mechanical Relay) N.C. 2 |
| Monitor Mode | ☆ Normal 3 | Set to Snow in instances where false door activations can result from blowing snow, leaves or rubbish in the door close area. | ☆ Normal 3 Snow 3 |
| Door Hold | ☆ Auto 4 | CAUTION Switch to OPEN to hold the door in the open position. | ☆ Auto 4 Open 4 |
| Doorway Learn | ☆ OFF 5 | Doorway Learn allows the 1 st row of detection to be focused inside the door close area without detecting the door movement. Note When Doorway Learn is turned ON, the sensitivity level of the inner row of detection is only at maximum when the outer rows of detection are activated. | ☆ OFF 5 ON 5 |
| Test Input Setting from Door Controller | ☆ OFF 6 | When connected to a door controller without a TEST input, set to "OFF". When connected to a door controller with a TEST input, set to "ON". Refer to [11.Timing Chart of events]. EN16005 To comply with EN16005 set to "ON". | ☆ OFF 6 Without TEST With TEST Without TEST ON 6 OFF 0v ON 0v |

8. DETECTION AREA WIDTH AND DEPTH ADJUSTMENT

CAUTION The above illustrated detection areas represent the actual position of the infrared beams. The actual detection area observed will vary depending on the sensor installation environment, object been detected and sensor settings. Please ensure that the detection area is set to conform to EN16005.

Detection Area Depth Adjustment: Inner 3 Rows

Detection Area Width Adjustment

Detection Area Depth Adjustment: Outer 2 Rows

9. APPLYING POWER AND THE "DOORWAY LEARN" SETTING

"Doorway Learn" is OFF
Ref section 7, Dip Switch Settings.

Upon power ON, the solid green LED turns on indicating that the sensor is in standby mode and ready to detect.

Presence Detection: It takes 10s after sensor power up for presence detection to be initiated on all rows of detection.
If before 10s has elapsed someone walks into the detection area it will take about 5s after the person leaves the detection zone for presence detection to be functional.

"Doorway Learn" is ON
Ref section 7, Dip Switch Settings.

Upon power ON, the Red LED indicates a door open relay output to begin the doorway learn process.

Green LED blinks for about 10s as the "door learn" process is carried out. Door opens/closes.

Door learn process complete, sensor in standby mode.

CAUTION **Presence Detection:** During the "Doorway Learn" process the outer 4 rows of detection on the HR100-CT sensor switch from motion detection to presence detection 10s after power ON. The inner "door learn" row of detection will switch from motion to presence detection after the "doorway learn" process is carried out.

"Doorway Learn" Failure & Recovery: If a person enters the detection area during the "doorway learn" process it may not be successfully completed. In this case the sensor will carry out the doorway learn process on door activations by a person in order to build an accurate image of the door open and door close position.

Note When Doorway Learn is turned ON, the sensitivity level of the inner row of detection is only at maximum when the outer rows of detection are activated.

General Caution:
When carrying out the following work, turn off sensor power.
※ When the floor condition is changed by placing a mat on the floor etc.
※ When the detection area pattern or sensor sensitivity is adjusted.

10. VERIFICATION OF OPERATION

After installation is completed "walk test" the sensor detection area. If the detection area is not as expected adjust the detection area as referred to in section 8 or increase the rows of detection using Dip switch (X) 3 & 4
If the detection area is still not as expected then the sensor sensitivity can be increased by turning the potentiometer clockwise. When the sensor detects even though there is nothing in the detection area the sensor sensitivity can be decreased by turning the potentiometer in the anti-clockwise direction.

11. TIMING CHART OF EVENTS

Safety Output Row 1, 2 / Test Input

Test Input: T1: 10±1 [mSec] App, T2: 11±1 [mSec] App

Test Response: DETECTION As response to TEST

Supplying DC12 to 24V, make current flow from Gray to Brown.

Break the current flow on test state.

11. TIMING CHART OF EVENTS (Continued)

Activation Output Row 2, 3, 4, 5

Activation Output: Dip Switch (Y) 2

12. DOOR MAINTENANCE WORK

When carrying out door maintenance work with power applied to the sensor on door controllers that are wired to "test" the sensor ensure to set the dip switches as below.

Note Keep in mind to return the dip switch settings to their original state once door maintenance work has been carried out.

Refer to [7.Dip Switch Settings].

13. SELF DIAGNOSTICS ERRORS

Technical problems with the HR100-CT sensor are indicated by a flashing Green/Red LED. The frequency of flashing indicates the type of problem as explained below.

| Flash Frequency | LED | Cause |
|-----------------|--------------|---|
| Fast | Green Red | Please replace the sensor. |
| Slow | Green Red | Confirm that the sensitivity potentiometer is set to maximum and re-power the sensor. If the error persists, set Dip Switch (X) 8 to "Low Reflection". |

14. TROUBLESHOOTING

| Problem | LED Status | Possible Cause | Solution |
|---|-------------------------------------|--|---|
| Door does not open when a person enters the detection area. | OFF | Sensor Connector not connected correctly. | Tighten or reconnect the connector. |
| | | Incorrect power supply voltage. | Apply proper voltage to the sensor. (AC/DC 12-24V) |
| | | Incorrect sensor wiring. | Double check sensor wiring. |
| Door opens and closes for no apparent reason (Ghosting). | Door Opens RED Door Closes GREEN | Object moving in the detection area. | Remove the moving object from detection area. |
| | | Sensitivity too high for the installation environment. | Reduce the sensor sensitivity. |
| | | Dust, frost or water droplet on the sensor lens. | Wipe the sensor lens clean and install a weather cover if necessary. |
| | | Detection area overlaps with that of another sensor. | Ensure different frequency setting for each sensor. |
| | | Detection of falling snow, insects, leaves etc. | Turn monitor mode Dip switch (Y) 3 to "Snow". |
| When Door opens or closes, LED ORANGE. | ORANGE | Detection row "ROW1" (ROW2: when "Doorway Learn" is turned ON) is focused too close to the door. | Adjust detection depth of Inner 3 rows away from the door. |
| | | Detection area changed, while ∞ infinity presence timer setting is in use. | Re-power the sensor or change the presence timer settings to 30 or 60 secs. |
| Door opens and remains in the open position. | RED | Incorrect sensor wiring. | Double check sensor wiring. |
| | | Reflected signal saturation. | Remove highly reflective objects from the detection area, or lower the sensor sensitivity. |
| | | Internal sensor error. | Replace the sensor. |
| | GREEN/RED FAST FLASH | Reflection of the transmitted infrared signal from the floor is too low. | Increase sensor sensitivity or change the "Reflection Diagnostics" Dip switch (X) 8 from "Normal" to "Low Ref". |
| | ORANGE blinking (Slow) | Door Hold (Dip switch (Y) 4 set to Open). | Turn "Door Hold" Dip switch (Y) 4 to Auto. |

15. HR100-CT EC DECLARATION OF CONFORMITY

| | | | |
|---|--|---|----------------------------------|
| Compiler of Technical File (EC Community) David Morgan Hotron Ireland Ltd 26 Dublin Street, Carlow, Ireland Ph: +353-(0)59-9140345 Fax: +353-(0)59-9140543 | Description of Product: HR100-CT Combined motion and presence detection sensor for the activation and safety of automatic doors. Technology used is Active Infrared Technology. | | |
| | Harmonized Standards Used: EN ISO 13849-1:2008 | Other Technical Standards Used: DIN 18650-1:2005 EN 16005:2012 | |
| Above EC Type Directives Certified by: TUV NORD CERT GmbH 30519 Hannover, Germany Identification No: 0044 | Declaration made by: Kaoru Musya General Manager, Honda Electron | Location of Declaration: Honda Electron Co., LTD. 1-23-19 Asahi-Cho, Machida-City, Tokyo, Japan | Date: 9th of Nov. 2012 |
| Directives Fulfilled: DIRECTIVE 2006/42/EC DIN 18650-1:2005 Powered pedestrian doors Part 1: Product requirements chapter 5.7.4 EN12978:2003 Industrial, commercial and garage doors and gates - safety devices for power operated doors and gates - Requirements and test methods EN62061:2005 Functional safety of electrical/electronic/programmable electronic safety-related systems EN ISO 13849-1:2008 Safety of machinery - Safety-related parts of control systems. EN 16005:2012 EC type examination 44 205 12 414283-001 | | | |

< Disclaimer > The manufacturer cannot be held responsible for below.

- Misinterpretation of the installation instructions, miss connection, negligence, sensor modification and inappropriate installation.
- Damage caused by inappropriate transportation.
- Accidents or damages caused by fire, pollution, abnormal voltage, earthquake, thunderstorm, wind, floods and other acts of providence.
- Losses of business profits, business interruptions, business information losses and other financial losses caused by using the sensor or malfunction of the sensor.
- Amount of compensation beyond selling price in all cases.



For More Information - Tel: +61 7 3205 1123 Email: info@rotech.com.au Web: www.rotech.com.au